

Aon Sprinkler Certification

Listing register of fire protection valves

27 January 2010

Cert. No.	Manufacturer	Description	Model	Listing Originator	Listing Date
TF-01	Cla-Val	Pressure Relief and Sustaining Valve	Cla-Val 50-01	Tyco Flow Control	22-May-08
TF-02	Cla-Val	Pressure Reducing Valve	Cla-Val 90-01	Tyco Flow Control	22-May-08
TF-03	Cla-Val	Pressure Reducing Valve	Cla-Val 92-01	Tyco Flow Control	29-May-08
TF-04	Cla-Val	Pressure Sustaining Valve	Cla-Val 92-01	Tyco Flow Control	29-May-08
V-09	Victaulic	Alarm Valve	Series 759 FireLock Alarm Check Valve	Steel and Tube	22-May-08
TY-028	Tyco	Deluge Valve	Model DV-5 Deluge Valve	Tyco Safety Products	1-Oct-08
TY-029	Tyco	Dry Pipe Alarm Valve	Model DPV-1 Dry Pipe Valve	Tyco Safety Products	1-Oct-08
TY-030	Tyco	Preaction System Double Interlock	Preaction system with DV-5 Valve, Double Interlock - Electric Pneumatic Actuation	Tyco Safety Products	1-Oct-08
TY-031	Tyco	Preaction System Single Interlock	Preaction System with DV-5 Deluge Valve, Single Interlock,.	Tyco Safety Products	1-Oct-08
V-12	Victaulic	Supervised Normally Closed Valve	Series 707 Firelock Butterfly Valve	Steel & Tube	22-Sep-08
V-13	Victaulic	Floor Zone Module	Series 747M Zone Control Riser Module	Steel & Tube	30-Sep-08
CV-01 Rev A	Cla-Val	Pressure Sustaining Valve	Cla-Val 92-01/692-01 Pressure Reducing/Sustaining valve	Cla-Val	6-Jan-09
CV-02 Rev A	Cla-Val	Pressure Reducing Valve	Cla-Val 92-01/692-01 Pressure Reducing/Sustaining valve	Cla-Val	6-Jan-09
CV-03	Cla-Val	Check Valve	582G Check Valve	Cla-Val	6-Jan-09
CV-04	Cla-Val	Tank In-Fill Valve	129-01/629-01 Float Valve	Cla-Val	6-Jan-09
V-15	Victaulic	Alarm Valve	Series 751 Firelock Alarm Check Valve	Steel & Tube	29-Jan-09
CV-05	Cla-Val	Pressure Relief Valve	50B-4KG-1 Pressure Relief Valve	Cla-Val	28-Jan-09
CV-06	Cla-Val	Pressure Relief and Sustaining Valve	Cla-Val 50-01	Tyco Flow Control	22-May-08
CV-07	Cla-Val	Pressure Reducing Valve	Cla-Val 90-01	Tyco Flow Control	22-May-08
CV-08	Cla-Val	Pressure Reducing Valve	Cla-Val 92-01	Tyco Flow Control	29-May-08
CV-09	Cla-Val	Pressure Sustaining Valve	Cla-Val 92-01	Tyco Flow Control	29-May-08
Val-22	Fivalco	Supervised isolation valves	Firefly and Fireriser butterfly valves	Steel & Tube	31-Aug-09
V-16	Victaulic	Preaction Valveset	FireLock NTX Preaction valve sets	Victaulic	1-Sep-09
Val-24	Fivalco	Check Valve	Fireriser Check Valve	Steel and Tube	25-Sep-09
Val-25	Reliable	Alarm Valve	Model E Alarm Check Valves	Steel and Tube	25-Sep-09
Val-26	Reliable	Preaction Valveset	DDX Single Interlock Dry Pilot Preaction System	Steel and Tube	25-Sep-09
Val-27	Reliable	Alarm Valve	Model E3 High Pressure Alarm Check Valves	Steel and Tube	28-Sep-09
Val-28	Reliable	Water Motor Alarm	Model C1 Mechanical Sprinkler alarm	Steel and Tube	28-Sep-09
V-10	Victaulic	Water Motor Alarm	Sries 760 FireLock Water Motor Alarm	Steel and Tube	22-May-08
Val-30	Global Safety Products	Supervised isolation valves	B0-G300 Monitored Isolation Valve	Steel and Tube	19-Oct-09
Val-31	Bonomi	Isolation Valve	Bonomi Ball Valve with Lockable handle	JJ Asmuss	5-Nov-09

Val-32	Tyco	Accelerator	Model QRS Electronic accelerator	Tyco	6-Nov-09
Val-33	Globe Fire Sprinkler Corp	Isolation Valves	Model GLR300W and GLR300G Grooved Butterfly Valves	Unifire	14-Jan-10
Val-34	Globe Fire Sprinkler Corp	Alarm Valve	Model H alarm Valves	Unifire	14-Jan-10
Val-35	Globe Fire Sprinkler Corp	Water Motor Alarm	Model WM Water Motor Alarm	Unifire	14-Jan-10

Notes	Reference
Refer cetificate for restrictions	Cross listed by Cla-Val - see certificate number CV-06
Refer cetificate for restrictions	Cross listed by Cla-Val - see certificate number CV-07
Refer cetificate for restrictions	Cross listed by Cla-Val - see certificate number CV-08
Refer cetificate for restrictions	Cross listed by Cla-Val - see certificate number CV-09
Use OEM Retard when needed	
Any deviations from Manufacturer's Data Sheet to be specifically approved.	UL Online Certifications Directory VLFT.EX6022
	UL Online Certifications Directory VLJH.EX6021
Specific project approval of releasing system required. For freezer applications only	UL Online Certifications Directory VPZV.EX6107
Any deviations from Manufacturer's Data Sheet to be specifically approved.	UL Online Certifications Directory VLFT.EX6022
	UL Online Certifications Directory HLXS.EX3784
Not suited for use with 10mm sprinklers	UL Online Certifications Directory VEOY.EX5986
Must be fitted with X46A Clean Flow Strainer	Certificate re-issued 28 Jabnuary 2009 with valve designation error corrected
Specific project approval required	Certificate re-issued 28 Jabnuary 2009 with valve designation error corrected
Protect control piping from freezing	
Trim to be modified to comply with NZS4541. When used in a type Y configuration, factory supplied by-pass trim must be used.	UL Online Certifications Directory VPLX.EX5193
To be fitted with X101 Position Indicator if discharge not visable.	UL Online Certifications Directory QXZQ.EX2855
Refer cetificate for restrictions	Cross listed by Tyco Flow Control - see certificate number TF-01
Refer cetificate for restrictions	Cross listed by Tyco Flow Control - see certificate number TF-02
Refer cetificate for restrictions	Cross listed by Tyco Flow Control - see certificate number TF-03
Refer cetificate for restrictions	Cross listed by Tyco Flow Control - see certificate number TF-04
Refer to certificate for details	
Maximum air pressures not to be exceded	
Max Working Pressure 21bar	
	Reliable Bulletin 418 Rev K
	Reliable Bulletins 735 Rev A,732 Rev C and 742
Max Working Pressure 21bar	Reliable Bulletin 410 Rev E
	Reliable Bulletin 612 Rev I
Maximum Working Pressure 17 bar	
Maximum Working Pressure 25 bar	

Install strictly in accordance with data sheet	Tyco Data Sheet TFP1100 May 2009
Maximum Working Pressure 20.7 bar	UL Online Listing Certificate VPLX.EX3148
Maximum Working Pressure 12 bar, unless supplied with DIN Class 16 flanges	UL Online Listing Certificate HLXS.EX6691
	UL Online Listing Certificate HLXS.EX6691